TCEQ

Texas Commission on Environmental Quality Form TCEQ-20700 - Instructions

General Instructions:

The purpose of form TCEQ-20700 Backflow Prevention Assembly Test and Maintenance Report (T&M Form) is to document the results of testing a backflow prevention assembly. The form can be completed in one of two ways:

- 1. The form can be printed and completed by hand, or
- 2. The form can be completed electronically through an electronic medium (tablet, laptop computer, etc.). The yellow areas on the form can be completed electronically.

NOTE: The form is intended to be completed on-site while testing is occurring. If the form is completed electronically, the electronic device must also be on-site for proper use of this form.

The form must be printed and signed by the Licensed Tester that performed the work, unless TCEQ approved electronic recording keeping is in use. The hardcopy original must be provided to the Public Water System (PWS) as specified in *Title 30 of the Texas Administrative Code 290.44(h)(4)(c)*.

Specific Instructions:

Please follow the instructions below when completing form TCEQ-20700:

- 1. Check boxes: If completing the form electronically, all check boxes can be selected to make the desired indication. Selecting a box will insert an "X" in the box.
- 2. When performing the test, if the "Initial Test" yields acceptable results, do not complete the "Repairs and Materials Used**" or "Test After Repairs" rows on the form.
- 3. Remarks: If completing the form electronically, the "Remarks" section of the form is expandable, which means the final report can be more than one page. All pages of the T&M Report must be submitted to the water system.
- 4. Testing completed by a licensed tester must be documented on one form. Any follow-up testing performed by a different tester must be documented on a separate form.

Things to remember:

- 1. Differential pressure gauges:
 - a. In order to prevent contamination, gauges used on potable water backflow prevention assemblies must **not** be used to test non-potable backflow prevention assemblies.
 - b. Gauges need to be tested for accuracy annually and that date plus the serial number and other gauge information must be correctly recorded on the form. This allows Public water systems to ensure that the gauges are in compliance.
- 2. Annual testing of backflow prevention assemblies (those installed to protect against health hazards) or differential pressure gauges is to occur no more than 12 months from the last test date.
- 3. A tester's license is based on the testing procedures described in the University of Southern California's 10th edition manual. These procedures are expected to be used when testing backflow prevention assemblies.
- 4. Type II assemblies: This form can only accommodate a Type II assembly with a single check bypass.

Texas Commission on Environmental Quality BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for recordkeeping *purposes:						
NAME OF PWS	S:	Walnut Creek Special Utility District				
PWS ID#:		TX1840008				
PWS MAILING ADDRESS:		P. O. Box 657 Springtown, TX 76082				
PWS CONTACT PERSON: Perry Day						
ADDRESS OF SERVICE:						
The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations						
and is certified to be operating within acceptable parameters. TYPE OF BACKFLOW PREVENTION ASSEMBLY (BPA):						
			Reduced Pressure Principle-Detector (RPBA-D) Type II			
□ Double Check Valve (DCVA) □			Double Check-Detector (DCVA-D) Type II □			
Pressure Vacuum Breaker (PVB) Spill-Resistant Pressure Vacuum Breaker (SVB)						
Manufacturer: Main: Bypass:			Size: Main: Bypass:			
Model Number: Main: Bypass		Bypass:		BPA Location:		
Serial Number: Main: Bypass:			BPA Serves:			
Reason for test: New Existing Replacement Old Model/Serial #						
Ten Daning District Propagation of the Propagation						
Is the assembly installed on a non-potable water supply (auxiliary)?						
TEST RESULT				Type II	PVB & SVB	
	Reduced Pressu	re Principle Assemb	oly (RPBA)	Assembly		
PASS D DCVA						
f 1		1	Relief Valve	Bypass Check	Air Inlet	Check Valve
FAIL 🗆	1st Check	2 nd Check***		31		
Initial Test	Held at psi	d Held at psid		Held at psid	Opened at	psid Held at
Date:	Closed Tight	Closed Tight	psid	Closed Tight	Did not open	psid
Time:	Leaked \Box	Leaked	Did not	Leaked \square	Did it fully open	Leaked \square
]	open 🔲	_	(Yes □ /No □	
Repairs and Main: Materials						
Used** Bypass:						
				[]	. [1 1
Test After		, I	-		Opened at	psid Held at
Repair	Closed Tight L	Closed Tight		Closed		psid
Date:				Tight \square		
Time:						
*** 2 nd check: numeric reading required for DCVA only						
Differential pressure gauge used: Potable: □ Non-Potable: □						
Make/Model:			Date tes	ted for accuracy	y:	
Remarks:						
IX-HIGINS.						
Company Name:			Licensed Tester Name (Print/Type):			
Company Address:			Licensed Tester Name (Signature):			
Company Phone	#:		BPAT License #	#	1	
1 -7 3110		<u> </u>	License Expirati			
	1		1	1 1 1		

The above is certified to be true at the time of testing.
* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]

^{**} USE ONLY MANUFACTURER'S REPLACEMENT PARTS